PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 6129	
DATE 23/08/2	Lo 2/
It is certified that an inspection team headed by Dr. N. S. Tolia (D.T. 0)	
BAGESHINAR (Name of Officers with Designation) from ST. JOSEPH'S SCHOOL (Name and Address Of the School) on	
17.08.2021 and found that the ST. JOSEPH'S SCHOOL, THOMAS	BU
(Name of School) has safe water drinking facilities for the students and members of staff of the institution/school and is maintaining a hygienic sanitation in the school premises/building and the campus as per the norms prescribed by Central/U.T Government.	
The above valid for a period of <u>03 YEARS</u>	
Signature with Seal Chief Medical Officer Name of the Officer Designation	

ST. JOBEPH'S SCHOOL
THUNAS BAGGSHWAR
26.36 42

(Name and Address of the Institution/School)



PRINCIPAL ST JOSEPH SCHOOL THUNAI, NADIGAON BAGESHWAR. U K. 263642

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated: 23 (03/20
It is certified that an inspection team headed by Dr. Prmod Singh Jangpangi
(Name of Officers with designation) from Dr. Prmad Singh Jamapangi CA. C. M. O. Bayes
(Name of Department/ Office) inspected the Health & family Wellaxe Department Bageshwar
(Name & Address of the school) on 25/05/2023 (date of inspection), checked the water test report
submitted by the school and found that the school has potable drinking water for students and staff of the
institution and is having provision for running water in the toilets and maintaining hygienic sanitation
condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 24/05/2024

Signature with Seal:

Designation: CA.C.M.O. Bageshway

Assistant Engineer of the Govt. Public Health Department (PHED)/ Authorised officer of the Local Body

Name & Address of the Office / Department

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

58 | Page

To

Princpal

Nadigaon Bages husar (Name & Address of the Institution)



District Level Water Quality Testing and Monitoring Laboratory Uttarakhand Jal Sansthan Bageshwar



Ph (O): 05694225237, E-mail: eeujsbgr@gmail.com



TC-10044

Test Report ID: 103/UJS/DLWQTML/2023-24

URL NO.: TC1004423000000001F Dated: 10-05-2023

WATER QUALITY TEST REPORT

Name and Address of Organization/	ST.Josep's School, Thunai, Bageshwar			
Customer Type of Source (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description	One sample collected Tap Water	
Reference Sample Identification:	DLWQTML/UJS/SJ-01		Date of Start of Analysis:09-05-2023	
Reference Sample Identification.			Date of End of Analysis:10-05-2023	
Pate and Time of Sample Received: 10-05-2023, 12:45 pm Sample Collected by:				

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit(BIS) In the Absence of alternative source	Std. Test Method
1	pН	8.37	6.5 to 8.5	No Relaxation	IS3025(Part11)1983,RA:2017: Electtrometric method
2	Total Dissolved Solids (TDS), mg/L, Max	150	500	2000	IS 3025 (Pt-16).1984 RA:2017: Gravimetric Method
3	Turbidity, NTU	0.53	1	5	IS 3025 (Pt-10),1984 RA :2017: Nephelometric Method
4	Total Alkalinity (as CaCO ₃), mg/L, Max	78	200	600	IS 3025 (Pt-23),1986 RA :2019: TitrimetricMethod
5	Total Hardness (as CaCO ₃), mg/L Max	90	200	600	IS 3025 (Pt-21),2009 (a) RA :2019:EDTA TitrimetricMethod
6	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Pt-): 2018
7	Chloride,mg/l, Max	26.73	250	1000	IS 3025 (Pt 32):1988, RA:2019: Argentometric Method)
8	'Colour, Hazen, Max	Less Than 05	5	15	IS 3025(Part -40)-2021 (Platinum Cobalt Visual Comparison Method
9	Calcium (as Ca), mg/L, Max	24	75	200	IS 3025(Part -40)-RA 2019 (EDTA Titrimetric Method
10	Magnesium (as Mg), mg/L, Max	7.29	`30	100	APHA 3500-Mg(B) ` Calculation Method

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

-End of Report-

The results listed refer only to tested sample and applicable parameters.
 This certificate is not be reproduced whole the promotional publicity or legal purpose without permission of authority of testing

of issue of test certificated unless otherwise agreed with customer. 3. The samples will be destroyed after titted as



District Level Water Quality Testing and Monitoring Laboratory Uttarakhand Jal Sansthan, Bageshwar

Ph (OFFICE): 05963-220038, E-mail: eeujsbgr@gmail.com

Test Report ID: 103-B/UJS/DLWQTML/2023-24

Dated: 10-05-2023

WATER QUALITY TEST REPORT

Customer Type of Source (Surface Water/ Ground	ST.Josep's School, Thunai, Bageshwar			
	Drinking Water		One sample collected Tap Water	
Water/ Drinking Water) Reference Sample Identification:	DLWQTML/UJS/SJ-01		Date of Start of Analysis:09-05-2023 Date of End of Analysis:10-05-2023	
Date and Time of Sample Received: 10-05-	e of Sample Received:10-05-2023, 12:45 pm		Customer	

		Bacterio	logical Parai	neters	
SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permasible Limit 31S) In the Absence of alternative source	Std. Test Method
1	Total Coliform, MPN/100ML	Absent	Absent	Absent	APHA 23rd Ed9223 B
2	E- Coli , MPN/100ML	Absent	Absent	bsent	APHA 23rd Ed9223.B

Remark: Above received water sample conforms to IS: 10500-2012 for drinking a rpose with respect to above tests.

(Er. K.C. Pant)

2

-End of Repor

1. The results listed refer only to tested sample and applicable particles.

2. This certificate is not be reproduced wholly or in past procedure subjects or legal purpose without permission of authority of testing laboratory.

3. The samples will be destroyed after fifteen days the Historical study issue of repositions. Unless otherwise agreed with customer.